LISTING SERVICE

LISTING No. 7165-1496:102 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Model FA-101, FA-102, FA-104 and FA-1025 fire alarm control units. Non-coded; automatic, manual, local, waterflow and sprinkler supervisory service. System components:

DM-102S	Supervisory Board (2 Zone)
RM-104	Quad Relay Board
AM-108	Annunciator Driver Board
WM-101	Walk Test Board
DM-102	Detection (2 Zone)

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices. This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7165-1477:102

12-10-97

Date Issued: **JUNE 19, 2001** *Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, *Supervising Deputy Program Manager*